



230 N Orange Ave Brea, CA 92821-4026
 Contractors License # 655104 C-10, A, B
 Phone: 714/990-9280
 Fax: 714/990-9285



PACIFIC INDUSTRIAL ELECTRIC INVENTORY

DATE: April 4, 2005

LOCATION: 3Y1-00o **ITEM INV. #** 123 **PIE ITEM #** XFMR-206

DESCRIPTION: TRANSFORMER, PADMOUNT

MFG. NAME: PAUWELS TRANSFORMER **CATALOG NO.:** _____

MODEL# ZB250144E480019 **SERIAL #:** 01A105995

"TURF HUGGER"

SPECIFICATIONS / INFORMATION

| | |
|--------------------------------|------------------------|
| VOLTS: <u>14400 480Y-277</u> | NEMA TYPE: <u>3R</u> |
| AMPS: _____ | FUSEABLE: <u>NO</u> |
| PHASE: <u>3</u> | FUSE TYPE: <u>NO</u> |
| Hz: <u>60</u> | HEIGHT: <u>72"</u> |
| POLES: <u>3</u> | LENGTH: <u>70"</u> |
| KVA: <u>2500</u> | WIDTH: <u>102"</u> |
| PRIMARY: <u>14400</u> | WEIGHT: <u>12315</u> |
| SECONDARY: <u>480Y-277</u> | KIRK KEY: <u>NO</u> |
| k AIC: _____ | NEW: <u>NO</u> |
| | PHOTO FILE: <u>YES</u> |

NOTES: BIL = HV 95KV- LV 30KV; CU wound; UNIT EQUIPED W/ ON/OFF (open / close) switch, radial feed and is fused.



TRANSFORMER NAME PLATE DATA

MANUFACTURE'S ADDRESS:


NAME: PAUWELS TRANSFORMER _____
STREET 1: _____
STREET 2: _____
CITY: WASHINGTON _____
STATE: MO _____
ZIP: 93090 _____

PHONE #: _____
FAX #: _____

D.O.M.: _____
OIL FILLED: YES _____
GAL. CAP. : 520 _____
SHIELDING: _____
DELTA / WYE: YES _____

COOLING CLASS: OA _____
CATALOG #: 0 _____
INSULATION SYS.: _____
RISE: 65°C _____
LIVE FRONT: NO _____

NOTES: 5.75% IMPEDENCE _____



| CONN.TAPS | VOLTAGE |
|-----------|---------|
| A | 14400 |
| B | 13800 |
| C | 13200 |
| D | 12470 |
| E | 12000 |
| F | 11540 |
| G | 11000 |
| | |

INVENTORY REMOVAL DATE: _____

PURPOSE: _____

