



230 N Orange Ave Brea, CA 92821-4026
 Contractors License # 655104 C-10, A, B
 Phone: 714/990-9280
 Fax: 714/990-9285



PACIFIC INDUSTRIAL ELECTRIC INVENTORY

DATE: July 27, 2005

LOCATION: Out **ITEM INV. #** 49 **PIE ITEM #** _____

DESCRIPTION: TRANSFORMER, PADMOUNT

MFG. NAME: VANTRAN ELECTRIC CORP. **CATALOG NO.:** _____

MODEL# CZ **SERIAL #:** 98V4483

SPECIFICATIONS / INFORMATION

VOLTS: <u>2400-1440 480Y-277</u>	NEMA TYPE: <u>3R</u>
AMPS: _____	FUSEABLE: <u>NO</u>
PHASE: <u>3</u>	FUSE TYPE: <u>N/A</u>
Hz: <u>60</u>	HEIGHT: _____
POLES: <u>3</u>	LENGTH: _____
KVA: <u>2500</u>	WIDTH: _____
PRIMARY: <u>2400 delta / 200 delta 4160 Grd Y/2400 x 12470</u>	WEIGHT: <u>19000</u>
SECONDARY: <u>480Y-277</u>	KIRK KEY: <u>NO</u>
k AIC: _____	NEW: <u>NO</u>
	PHOTO FILE: <u>YES</u>

NOTES: Unit is marked "NR2956"; equipped to be switchable for "Dual Voltage" & "Delta - Wye"; Has blackTransport frame / skid; Unit is Caterpillar Yellow Color



230 N Orange Ave Brea, CA 92821-4026
 Contractors License # 655104 C-10, A, B
 Phone: 714/990-9280
 Fax: 714/990-9285



TRANSFORMER NAME PLATE DATA

MANUFACTURE'S ADDRESS:


NAME: VANTRAN ELECTRIC CORP. _____
STREET 1: _____
STREET 2: _____
CITY: Waco _____
STATE: TX _____
ZIP: _____

PHONE #: _____
FAX #: _____

D.O.M.: _____
OIL FILLED: YES _____
GAL. CAP. : 800 _____
SHIELDING: _____
DELTA / WYE: YES & WYE-WYE _____

COOLING CLASS: OA _____
CATALOG #: 0 _____
INSULATION SYS.: _____
RISE: 65°C _____
LIVE FRONT: YES _____

NOTES: 5.75% IMPEDENCE @ 85°C



Delta Voltage	Wye Voltage	TAPS
8320	14400	A
7970	13800	B
7737	13400	C
7620	13200	D
7200	12470	E
2400	4160	E

INVENTORY REMOVAL DATE: 7/27/2005

PURPOSE: on rental

