



230 N Orange Ave Brea, CA 92821-4026
 Contractors License # 655104 C-10, A, B
 Phone: 714/990-9280
 Fax: 714/990-9285



PACIFIC INDUSTRIAL ELECTRIC INVENTORY

DATE: April 4, 2005

LOCATION: 3Y1-00o **ITEM INV. #** 56 **PIE ITEM #** XFMR-209

DESCRIPTION: TRANSFORMER, PADMOUNT

MFG. NAME: PAUWELS TRANSFORMER **CATALOG NO.:** _____

MODEL# ZB250144E480019 **SERIAL #:** 01A105993

"TURF HUGGER"

SPECIFICATIONS / INFORMATION

VOLTS: <u>14400 480Y-277</u>	NEMA TYPE: <u>3R</u>
AMPS: _____	FUSEABLE: <u>NO</u>
PHASE: <u>3</u>	FUSE TYPE: <u>NO</u>
Hz: <u>60</u>	HEIGHT: <u>72"</u>
POLES: <u>3</u>	LENGTH: <u>70"</u>
KVA: <u>2500</u>	WIDTH: <u>102"</u>
PRIMARY: <u>14400</u>	WEIGHT: <u>12315</u>
SECONDARY: <u>480Y-277</u>	KIRK KEY: <u>NO</u>
k AIC: _____	NEW: <u>NO</u>
	PHOTO FILE: <u>YES</u>

NOTES: BIL = HV 95KV- LV 30KV; CU wound; UNIT EQUIPED W/ ON/OFF (open / close) switch, radial feed and is fused. (Unit has #9 marking)



TRANSFORMER NAME PLATE DATA

MANUFACTURE'S ADDRESS:


NAME: PAUWELS TRANSFORMER _____
STREET 1: _____
STREET 2: _____
CITY: WASHINGTON _____
STATE: MO _____
ZIP: 93090 _____

PHONE #: _____
FAX #: _____

D.O.M.: _____
OIL FILLED: YES _____
GAL. CAP. : 520 _____
SHIELDING: _____
DELTA / WYE: YES _____

COOLING CLASS: OA _____
CATALOG #: 0 _____
INSULATION SYS.: _____
RISE: 65°C _____
LIVE FRONT: NO _____

NOTES: 5.75% IMPEDENCE _____



CONN.TAPS	VOLTAGE
A	14.4 KV
B	13.8 KV
C	13.2 KV
D	12.47 KV
E	12 KV
F	11.54 KV
G	11 KV

INVENTORY REMOVAL DATE: _____

PURPOSE: _____

